

EN 16035 Hardware Performance Sheet (HPS)

DL 710

Test report no. P803439B

Building hardware identification

Manufacturer: DORMA Sverige AB, Industrievägen 14, 14178 Solna

Manufacturer's product reference: DL 710

Type of building hardware: locks and latches

EN building hardware product standard(s): EN 12209

Classification(s): 3 | X | 9 | 1 | 1 | 0 | G | I - | B | B | 2 | 1 | 0

Main dimensions [mm]: 225x105x64

Remarks: --

Test evidence

Material of door set: steel

Mounting of building hardware: Product concealed

Type of door set: hinged, single leaf door set

Door opening direction: into the oven

Isolation: Insulated

Door tested: latched

Performance level(s)

Performance: fire resisting and smoke control doorset

Test method: EN 1634-1

Date: 04.12.2008

Test report issued by: SP Technical Research Institute of Sweden

Classification: EI 2 60min.

Width of primary leaf: 1000mm

Width of secondary leaf: --

Door leaf height: 2100mm

Door thickness: --

Mass of primary leaf: --

Mass of secondary leaf: --

Restrictions: --

Installation Instructions: --

20180326_HPS_DL_710_EN.docx