

EN 16035 Hardware Performance Sheet (HPS)

DH 711

Test report no. P803522A

Building hardware identification

Manufacturer: DORMA Sverige AB, Industrivägen 14, 171 48 Solna

Manufacturer's product reference: DH 711

Type of building hardware: Lever handle

EN building hardware product standard(s): --

Classification(s): --

Main dimensions [mm]: 110x39x34

Remarks: --

Test evidence

Material of door set: timber

Mounting of building hardware: Surface mounted, product outside the oven, inside the oven

Type of door set: hinged, single leaf door set

Door opening direction: into the oven

Isolation: Insulated

Door tested: latched

Performance level(s)

Performance: fire resisting and smoke control doorset

Test method: EN 1634-1

Date: 05.12.2008

Test report issued by: SP Technical Research Institute of Sweden

Classification: EI 2 32min.

Width of primary leaf: 995mm

Width of secondary leaf: --

Door leaf height: 2090mm

Door thickness: --

Mass of primary leaf: --

Mass of secondary leaf: --

Restrictions: --

Installation Instructions: --

20180404_HPS_DH_711_EN.docx