

Materialprüfungsamt Nordrhein-Westfalen - 44285 Dortmund

dormakaba Deutschland GmbH
DORMA Platz 1
58256 Ennepetal
Germany

Ihr Zeichen: PS
Ihre Nachricht vom: 28.03.2022

Mein Zeichen: mei
(Bitte stets angeben!)

Sachbearbeiter: Meinks
Telefon: +49 (0)231 4502-493
Telefax: +49 (0)231 4502-586
E-Mail: meinks@mpanrw.de

Datum: 10.05.2022

Extension of validity of a test certificate.

Dear Ladies and Gentlemen,

Concerning the results of the initial type test carried out with the controlled door closing device TS 93 EN 2-5 B/G, you applied for the extension of validity of a test certificate no. 120370597-13. The tests have been carried out on the base of the DIN EN 1154:1997-05 (see test report no. 120370597-01).

Today the EN 1154:1996/A1:2002/AC:2006 is valid.

The changes, which have been made within the revision of this version of the DIN EN 1154, have no influence to the results and the classification of the door closer TS 93 EN 2-5 B/G.

You have also assured that the door closer was not modified since the initial type test.

Therefore, the validity of the test certificate no. 120370597-13 is extended up to December^{1st} 2026.

Best regards

By order



Th. Meinks
Regierungsbauamtmann



Test Certificate No. 12 0370 5 97-13

1. copy

Contracting party

Dorma GmbH & Co. KG
 Breckerfelder Str. 42-48
 D-58256 Ennepetal

Date of order: 25.06.1997
Receive of sample: 23.06.1997
Date of test: 23.06.1997 to 02.12.1997

Order

Testing of controlled door closing devices (overhead door closer surface mounted) for fire-/ smoke-doors in accordance with EN 1154: 1997-05.

Object of test

Overhead door closers surface mounted with hydraulic damping and slide channel arm assembly "DORMA TS 93B EN 2-5".

Overhead door closers surface mounted with hydraulic damping and slide channel arm assembly door closer "DORMA TS 93G EN 2-5"

Description of the test and test results

See test report no. . 12 0370 5 97-01.

Evaluation of the test results and the classification

The door closer „DORMA TS 93“ fulfill the requirements of 1154: 1997-05 and shall be classified according to sect. 4 as follows:

Type	Classification key					
DORMA TS 93B EN 2-5 Installation acc. to appendix 1	4	8	2 5	1	1	4
DORMA TS 93B EN 2-5 Installation acc. to appendix 2	3	8	2 5	1	1	4
DORMA TS 93G EN 2-5 Installation acc. to appendix 3	4	8	2 5	1	1	4
DORMA TS 93G EN 2-5 Installation acc. to appendix 4	3	8	2 5	1	1	4

Hint:

The manufacturer has to suggest in the mounting instructions, that it is not allowed to adjust the door closer to size 2 if it is used with fire-/smoke doors.

Dortmund, translated on January 16.01.2018
 Im Auftrag




Th. Meinks
 Regierungsbauberinspektor

This is the English translation of "Test Certificate No. 12 0370 5 97-13". The original version is in German language and was signed by H. Jansen on October, 7th 2011. The validity of this test certificate expires 01.12.2011. In case of any misunderstandings the signed German paper version is valid only.. The results of the tests are exclusively in relation to the test piece indicated above. Test reports may without the consent of the MPA NRW only be published or reproduced in accordance with their unaltered form and content. The abbreviated reproduction of a test certificate is only permissible with the consent of the MPA NRW. This test certificate comprises 1 page(s) and 4 appendices.







