

EN 16035 Hardware Performance Sheet (HPS)

TS 97

Test report no. DMT-DO-50-730-R1

Building hardware identification

Manufacturer: dormakaba Deutschland GmbH, DORMA Platz 1, 58256 Ennepetal

Manufacturer's product reference: TS 97 EN 2-4

Type of building hardware: Controlled door closing device surface mounted

EN building hardware product standard(s): EN 1154

Classification(s): 3 | 8 | 2-4 | 1 | 1 | 1 | 3

Main dimensions [mm]: 340x37x49

Remarks: --

Test evidence

Material of door set: timber

Mounting of building hardware: Surface mounted, product outside the oven

Type of door set: single leaf door set

Door opening direction: outside the oven

Isolation: insulated

Door tested: latched

Performance level(s)

Performance: Fire and smoke control door set

Test method: EN 1634-1

Date: 24.04.2020

Test report issued by: DMT Lathen

Classification: EI 2 93 min., EI 1 93 min.

Width of primary leaf: 1235mm

Width of secondary leaf: --

Door leaf height: 2485mm

Door thickness: 63mm

Mass of primary leaf: --

Mass of secondary leaf: --

Restrictions: --

Installation Instructions: --

20200508_HPS_TS_97_EN_2-4_EN.docx

This document was prepared digitally and is valid without signature
Published by product-compliance.dach@dormakaba.com

EN 16035 Hardware Performance Sheet (HPS)

TS 97

Test report no. 141929

Building hardware identification

Manufacturer: dormakaba Deutschland GmbH, DORMA Platz 1, 58256 Ennepetal

Manufacturer's product reference: TS 97 EN 2-4

Type of building hardware: Controlled door closing device surface mounted

EN building hardware product standard(s): EN 1154

Classification(s): 3 | 8 | 2-4 | 1 | 1 | 1 | 3

Main dimensions [mm]: 340x37x49

Remarks: --

Test evidence

Material of door set: timber

Mounting of building hardware: Surface mounted, product inside the oven

Type of door set: single leaf door set

Door opening direction: into the oven

Isolation: insulated

Door tested: unlatched

Performance level(s)

Performance: Fire and smoke control door set

Test method: EN 1634-1

Date: 05.10.2004

Test report issued by: Warrington Fire Research

Classification: EI 2 66min.

Width of primary leaf: 925mm

Width of secondary leaf: --

Door leaf height: 2038mm

Door thickness: 58mm

Mass of primary leaf: --

Mass of secondary leaf: --

Restrictions: --

Installation Instructions: --

20200508_HPS_TS_97_EN_2-4_EN.docx

This document was prepared digitally and is valid without signature
Published by product-compliance.dach@dormakaba.com