

Materialprüfungsamt Nordrhein-Westfalen - 44285 Dortmund

DORMA Holding GmbH + Co. KGaA
Breckerfelder Str. 42 - 48
58256 Ennepetal
Germany

Ihr Zeichen: Vogel
Ihre Nachricht vom : 23.02.2009
Unser Zeichen: 120001391.10-02
Durchwahl: 493
Direktfax: +49 (0)231 4502 586
E-Mail: meinks@mpanrw.de
Datum: 16.03.2009

Extension of validity of a test certificate.

Dear Mr. Vogel,

Concerning the results of the initial type test carried out with the controlled door closing device DORMA RTS 85 EN 3, EN 4, EN 5 you applied for the extension of validity of test certificate no. Nr. 120001391.10-02.

The tests have been carried out on the base of the DIN EN 1154:1997-05 (see test report no. Nr. 120001391.10-01).

Today the DIN EN 1154: 2003-04 is valid.

The changes which have been made within the revision of this version of the DIN EN 1154 have no influence to the results and the classification of the door closer DORMA RTS 85 EN 3, EN 4, EN 5.

You have also assured that the door closer was not modified since the initial type test.

Therefore the validity of the test certificate no. Nr. 120001391.10-02 is extended up to March, 1st 2014.

Best regards
By order



H. Jansen
Head of the test laboratory