

A thick, black vertical bar on the left side of the page, with two white squares positioned at the top and middle.

Product Certificate

DORMA-Glas GmbH
herewith certifies
that the product

Door rail with BTS-insert

Art.-No. 04.101

Top patch

Art.-No. 03.110

has been tested in an endurance test according to EN 1154.
This took place in a series of exemplary tests; the fittings were
mounted to a glassdoor with 100 kg weight.
Door width: 1100mm, Door height: 2000mm.
The complete door fulfils the demand

500.000 operations (cycles)

Bad Salzufen, 28.04.2006

Dipl.-Ing.
Thomas Vogler
Division Glass
Mechanical Design Management

DORMA-Glas GmbH
Max-Planck-Str. 33-45
D-32107 Bad Salzufen