

# **EC Certificate of Conformity**

## **0432 – CPD – 0173**

In compliance with Council Directive 89/106/EEC of 21 December 1988 on the approximation of laws, regulations and administrative provisions of the Member States relating to construction products (the Construction Products Directive or CPD), as later amended, it has been stated that the construction product

### **Electric strikes DORMA**

Electromechanical striking plates for doors  
as detailed on appendix 1,

produced in the factory and placed on the market by

**DORMA GmbH + Co. KG**  
**Dorma Platz 1**  
**58256 Ennepetal**  
**Germany**

is submitted by the manufacturer to a factory production control and to the further testing of samples taken at the factory in accordance with a prescribed test plan and that the notified body No. 0432 - MPA NRW - has performed the initial type-testing for the relevant characteristics of the product, the initial inspection of the factory and of the factory production control and performs the continuous surveillance, assessment and approval of the factory production control.

This certificate attests that all provisions concerning the attestation of conformity and the performances described in Annex ZA of the standard

**DIN EN 14846 :2008-11**  
**(EN 14846: 2008-08 (D))**

were applied and that the product fulfils all the prescribed requirements.

This certificate was first issued on 01.03.2013 and remains valid as long as the conditions laid down in the harmonised technical specification in reference or the manufacturing conditions in the factory or the FPC itself are not modified significantly.

Dortmund, 01.03.2013



Dip.-Ing. H. Jansen  
head of the certification body

---

THIS CERTIFICATE COMPRISES ONE (1) PAGE AND ONE (1) APPENDIX

THIS DOCUMENT WAS ORIGINALLY WRITTEN IN GERMAN. IN CASE OF DOUBT THE GERMAN VERSION SHALL PREVAIL.

## Fire 447

Classification

3	S	8	E	0	L	2	1	3
---	---	---	---	---	---	---	---	---

options: RR – monitor contact,  
 Lucky Strike – simulates AC voltage by use of DC voltage,  
 GL-Modul – rectifier modul,  
 Easy Adapt – latch guide.

voltages: 6-12 V AC/DC, 12 V AC, 24 V DC, 12-24 V DC, 12-24 V AC/DC.

---

## Smoke

Classification

3	S	8	A	0	L	2	1	3
---	---	---	---	---	---	---	---	---

options: RR – monitor contact,  
 Lucky Strike – simulates AC voltage by use of DC voltage,  
 GL-Modul – rectifier modul,  
 Easy Adapt – latch guide.

voltages: 6-12 V AC/DC, 12 V AC, 24 V DC, 12-24 V DC, 12-24 V AC/DC.

---

## Fire 448

Classification

3	S	8	D	0	L	2	1	3
---	---	---	---	---	---	---	---	---

options: RR – monitor contact,  
 Lucky Strike – simulates AC voltage by use of DC voltage,  
 GL-Modul – rectifier modul,  
 Easy Adapt – latch guide.

voltages: 6-12 V AC/DC, 12 V AC, 24 V DC, 12-24 V DC, 12-24 V AC/DC.

---

## Smoke 448

Classification

3	S	8	A	0	L	2	1	3
---	---	---	---	---	---	---	---	---

options: RR – monitor contact,  
 Lucky Strike – simulates AC voltage by use of DC voltage,  
 GL-Modul – rectifier modul,  
 Easy Adapt – latch guide.

voltages: 6-12 V AC/DC, 12 V AC, 24 V DC, 12-24 V DC, 12-24 V AC/DC.