

Test Certificate No. 12 0253 7 98-02

Contracting Party

DORMA GmbH & Co. KG
P.O. Box 40 09
D-58247 Ennepetal / Germany

Assignment

Testing of controlled door closing devices (door closer) in accordance with DIN EN 1154: 1997-05 (Ref. No. EN 1154: 1996 D). The tests are to be including the additional requirements according to annex A of DIN EN 1154.

Description of Samples

Overhead door closer surface mounted with sliding arm in accordance with illustration C.1.1 of DIN EN 1154
„cam-action door closer DORMA TS 93 B EN 5-7“,
door leaf fixing on the pull side, see appendix 1,
„cam-action door closer DORMA TS 93 G EN 5-7“,
transom fixing on the pull side, see appendix 2.

Description of the Test and Test Results

See Test Report No. 12 0253 7 98-01.

Evaluation of the Test Results


The door closer **„DORMA TS 92 B/G EN 5-7“** fulfils the requirements of the DIN EN 1154.
It is classified as follows in accordance with sec. 4 of DIN EN 1154:

4	8	7 5	1*)	1	4**)
---	---	--------	-----	---	------

*) The tests in accordance with A6 of the EN 1154 were conducted in default of the harmonised test procedure with prEN 1634-1 and 1634-3 according to the provision to the national norms DIN 4102-5 and DIN 18095-2. In other member countries of the EU, other substantiation procedures can be required.

***) An evaluation of the appearance of the test piece was not conducted, see 6.2 of the DIN EN 1670: 1998-12.

Dortmund, December 7th, 1999



Dipl.-Ing. H. Jansen
Regierungsbauamtsrat



This is the English version of „Prüfzeugnis Nr. 12 0253 7 98“.

The validity of this certificate expires on October 1st, 2003

The results of the tests are exclusively in relation to the test piece indicated above. Test certificates may without the consent of the MPA NRW only be published or reproduced in accordance with their unaltered form and content.

The abbreviated reproduction of a test certificate is only permissible with the consent of the MPA NRW

This test certificate comprises 1 page and 2 appendixes.

