


Fire Safety

Common Fire Door Failures



Self Closing device
63% stated the most common fault was the Fire Door not closing properly.



Damage


Almost 1 in 6 had damage to the door leaf.

61%

Faulty Fire Seals Over 61% of fire doors inspected had problems with fire or smoke seals.


Incorrect Signage

More than a third had incorrect signage.



Unsuitable Hinges

Almost one in five had unsuitable hinges.



Excessive Gaps

230

More than 230 (34%) fire doors inspected had excessive gaps between the door and it's frame (over 3mm).